

Construction Distance Chart Quick Reference Guide

COMPONENT	WELL	SEPTIC FIELD	SEPTIC TANK
RESIDENTIAL SWIMMING POOL	5 FEET	20 FEET	10 FEET
GARAGE/POLE BARN/SHEDS ON SLAB	5 FEET	0 FEET BUT RECOMMEND BUFFER OF 10FT	0 FEET BUT RECOMMEND BUFFER OF 10FEET
BUILDING ADDITION	5 FEET TO EXISTING WELL, 20 FEET IF NEW WELL IS DRILLED	25 FEET	10 FEET
BUILDING ADDITION ON SLAB	5 FEET TO EXISTING WELL, 20 FEET IF NEW WELL IS DRILLED	15 FEET	10 FEET BUT CAN BE AS CLOSE AS 5FEET WITH LOCAL BOH APPROVAL
NEW CONSTRUCTION	25 FEET	25 FEET	10 FEET
DECKS	WELL CAN BE UNDER DECK IF THERE IS ACCESS	10 FEET	TANK CAN BE UNDER DECK IF THERE IS ACCESS FOR PUMPING
IN GROUND OIL TANK	25 FEET	NA	NA
WELL	NA	100 FEET	50 FEET(100 FEET FOR ALEXANDRIA, EAST AMWELL, READINGTON,HIGHBRIDGE)
PROPERTY LINE	NA	10 FEET ALEXANDRIA, CLINTON TWP & HIGH BRIDGE: 20 FT EAST AMWELL: 25 FT READINGTON: 15 FT	5 FEET ALEXANDRIA, HIGH BRIDGE & READINGTON: 15 FT EAST AMWELL: 25 FT